



VP	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48
Control panel	3x0.5 ^Ø	3x0.5 ^Ø	5x0.5 ^Ø	2x0.5 ^Ø	2x0.5 ^Ø	2x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	2x0.75 ^Ø	2x0.75 ^Ø	2x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	2x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	2x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	2x0.5 ^Ø						
	MODBUS RS485 connection	External control	External stop	Fire system	OVR control	Common	Return water temp. sensor	B5	B1	Supply temp. sensor	Humidifier control	TG3	TG2	TG1	S2	S1	Humidity sensor	B9	Air quality sensor	B8	Exhaust air pressure sensor	B7	Supply air pressure sensor	B6	Supply/exhaust air damper actuator	FC1/2	Run	Alarm	Common	Common	Common	DX	Heating	Cooling	Operation	Common	Water pump/stop alarm											

